
From: brice gordon [REDACTED]
Sent: Friday, January 13, 2017 7:30 PM
To: Jeffrey Epstein
Cc: Rich Kahn
Subject: LSJ RO Plant

Jeffrey

Confirming the RO Plant on LSJ is now running on auto. The Profibus repeater was replaced this morning, this cleared the E stop alarm. I also have a copy of the RO plant PLC program, and are working on replacing the existing PLC as precautionary measure.

The next stage is to sort out a PMA with someone/company for the Plant.

regards

Brice Gordon

[REDACTED]