
From: Richard Kahn [REDACTED]
Sent: Friday, February 6, 2015 7:48 AM
To: Jeffrey Epstein
Subject: Fwd: ZDC- Damage to RC High Voltage Line

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue, 4th Floor
New York, NY 10022
[REDACTED]

Begin forwarded message:

<=lockquote type="cite">
From: Brice Gordon [REDACTED]
Date: February 5, 2015 at 8:17:32 PM EST
To: Rich Kahn [REDACTED]
Cc: Zorro Ranch= [REDACTED]>=br/>Subject: ZDC- Damage to RC High Voltage Line

Rich
As discussed this morning

Yesterday afternoon, Steve was trenching the new line from the Irrigation vault RC to Well 4, when he accidentally caught a high voltage feed to the Qwest Microwave Tower.

This took out power to both the Quest Tower and RC

Fortunately he just broke the conduit and pulled the Cable (pic 3 & 4) from the pole (Pic 2) and the Junction box (Pic 1) located at the office

Carlos was spotting for him, but did not see the Cable in time to stop Steve from lifting it with the backhoe.

Please note this line is not indicated on any As Built Plan for RC

It was buried approx 3 Feet in the ground, as opposed to the required 4ft

There was no warning tape buried above the line to indicate buried electrical line.

CNME was informed and came on sight to repair, they had no record of this cable in their data base. They pulled the cable back to both auction box and pole, replaced auction box terminals, replaced transformer fuse on pole. Power was established at both location at 11:20 pm

This work took 5 1/2 hours to perform.

CNME will need to return to repair conduit, they intend to be back on site tomorrow morning.

There will be charges for this work, we will try and clarify these tomorrow.

=/div>
Brice Gordon=div>Stanley, NM



=div>

=