

---

**From:** brice gordon [REDACTED]  
**Sent:** Monday, February 27, 2017 2:28 PM  
**To:** jeffrey E.  
**Cc:** Richard Kahn  
**Subject:** Re: LSJ HP Pump Replacement Rev1

thank you

Rich, I will separate out attached invoices, and forward with wiring instructions

On Mon, Feb 27, 2017 at 10:09 AM, jeffrey E. <jeevacation@gmail.com <mailto:jeevacation@gmail.com> > wrote:

ok

On Sun, Feb 26, 2017 at 7:44 AM, brice gordon [REDACTED] > wrote:

Jeffrey

=/div>

attached are quotes for the replacement the HP Pump, Spare parts and Pre Filter for the LSJ RO Plant

E-Mail of Recommendation from Patrick Adams TSG

Previous report E Mailed to you Feb 17th=/div>

Comparison of Cost Report

TSG proposal for Danfoss Pump

Replacement of the HP Pump, Spare Parts and Shipping \$ 45,959.70 USD

(Lead Time 4-6 Weeks to Tropical=Fl)

Pre Filter	=C2	=A0	=C2	\$ 4,707.46
------------	-----	-----	-----	-------------

Protec Membran= Parts	=A0	\$= 2526.80
-----------------------	-----	-------------

PLC Reprogram	=C2	=A0	\$=1500.00 (Verbal)
---------------	-----	-----	---------------------

Installation	=	=A0	=C2	\$ 6000.00 (estimated)
--------------	---	-----	-----	------------------------

Estimated total	=A0	=C2	=A0	\$60,693.96
-----------------	-----	-----	-----	-------------

=he E Mail from Patrick, in broad strokes explains the recommendation to go=with this pump.

The plan is to get Patrick to LSJ Mid March, to do critical membrane service, training and then back again to do pump install.

LSJ personal will be required to assist.

We need to do a Membrane service to relieve the high pressure situation on the existing HP Pump and also calibration of the post water treatment systems.

<=iv>The order of Protec parts are critical if you wish to still make water, and hopefully extend the life to the Existing HP Pump

One other issue that needs to be addressed is the Control Panel that was Saturated with Sea Water in 2014.

Patrick will re=iew this whilst on sight, and forward recommendations.

Can we proceed with purchasing?

=div>Brice Gordon

[REDACTED]

--

please note

The information contained in this communication is confidential, =ay be attorney-client privileged, may constitute inside information, an= is intended only for the use of the addressee. It is the property ofJEE Unauthorized use, disclosure or copying of this communication o= any part thereof is strictly prohibited and may be unlawful. If you ha=e received this communication in error, please notify us immediately by=br>return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com> , and destroy this communicat=on and all copies thereof, including all attachments. copyright -all ri=hts reserved

--

Brice Gordon

[REDACTED]