
From: Jermaine Ruan [REDACTED]
Sent: Wednesday, August 2, 2017 4:41 PM
To: Jeffrey Epstein
Cc: Ann Rodriguez
Subject: FYI: Solar at cabrita point cabinet

Good Day Boss

FYI: My findin= at the pole showed when I install the new APC Backup.

The subcontract brought his bucket truck to install=C2♦the new APC and found that the previous battery backup that Dann= V installed was installed incorrectly (all the power cables were plu=ged into the surge side vs the battery side).

We=install the new APC correctly so that if the there is an outage it will ho=d for a few hours until the power returns.

Do yo= still want to continue the solar generator project?

<=div>
Regards
J Ruan