
From: Jeffrey <jeevacation@gmail.com>
Sent: Friday, April 27, 2012 8:41 PM
To: brice gordon
Subject: Re: Libray

How did we discover?

Sorry for all the typos .Sent from my iPhone

On Apr 27, 2012, at 1:32 PM, [REDACTED] > wrote:

> update on library system
>
> 1. both dehumidifiers where down, one needs a new condenser the other
> had w=s locked out and had to be reset
>
> 2. It has been determined that only one recirculating pump should be on at=a time.
> when we commissioned the unit there was no mention at any time that we
> had=to close this valve manual and rotate pumps monthly basic to much water passing over the coil to quickly. Trane
> did not even p=c k this up. !!
>
>
> new condenser will be ordered, this should be covered by warranty.
> Will ge= David to review controls for dehumidifiers so we can view in
> mechanical ro=m since units are in attic space
>
> humidity down to 67% and dropping
>
>
>
> --
> Brice Gordon
> Little Saint James
> USVI
> Phone: [REDACTED]
>
<?xml version=.0" encoding=TF-8"?>
<!DOCTYPE plist PUBLIC "-//Apple//DTD PLIST 1.0//EN" "http://www.apple.com/DTDs/PropertyList-1.0.dtd">
<plist version=.0">
<dict>
 <key>date-last-viewed</key>
 <real>0.0</real>
 <key>date-received</key>
 <real>1335559179</real>
 <key>flags</key>
 <integer>8590195713</integer>
 <key>original-mailbox</key>
 <string>imap://jeevacation@imap.gmail.com/%5BGmail%5D/All%20Mail</string>

```
<key>remote-id</key>
<string>219720</string>
</dict>
</plist>
```