
From: LSJ <[REDACTED]>
Sent: Thursday, March 9, 2017 9:02 PM
To: jeffrey E.
Subject: Surge Protection
Attachments: IMG_4709.JPG; Untitled attachment 00155.txt

This what I'm talking about

Regarding surge protection

These have saved multiple device since there installation The other day the unit at Well b was hit Saving Well controller and 3 phase converter