
From: brice gordon <[REDACTED]>
Sent: Wednesday, October 19, 2016 9:44 PM
To: jeffrey E.
Subject: Re: LSJ RO Plant

Still working on manual
override
Danny will be reaching out PLC manufacture tomorrow

Sent from my iPhone

On Oct 19, 2016, at 12:51 PM, jeffrey E. <jeevacation@gmail.com <mailto:jeevacation@gmail.com>> wrote:

Manual override ok

On Wednesday, 19 October 2016, brice gordon <[REDACTED]> <mailto:[REDACTED]>
wrote:

Jeffrey

The RO plant on LSJ is still down
Reefco was out yesterday to review situation
16 x 32 MA fuses had taken a hit
Even after these were replaced the plant would still not operate
TSG have been contacted and are working remotely to determine problem
Danny is trying to figure out a way to bypass control program and run plant manually. At this time there is enough water for 2, possibly three days
We should know by 3pm if we can run system manually

Sent from my iPhone

--

please note

The information contained in this communication is
confidential, may be attorney-client privileged, may
constitute inside information, and is intended only for

the use of the addressee. It is the property of

JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this

communication in error, please notify us immediately by

return e-mail or by e-mail to jeevacation@gmail.com <<mailto:jeevacation@gmail.com>> , and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved