
From: jeffrey E. <jeevacation@gmail.com>
Sent: Thursday, October 27, 2016 2:45 PM
To: brice gordon
Subject: Re: GSJ Heli Pad

Call cell

On Thursday, 27 October 2016, brice gordon <bgordon.lsj@gmail.com <mailto:bgordon.lsj@gmail.com> > wr=te:

Jeffrey

Attached photo's of Heli Pad for your reference

<=div>

as you can see there are multiple issues with finish.

<=r>

1. Heavy Material who supplied the concrete, screwed up the recipe by adding to much retarder to the mix.
2. No= enough mix to finish pour.

I have spoken to EB t=is morning, they will be forwarding an outline on how they propose to addr=ss the above issues

I would recommend we self per=orm Hut Pad and find another contractor to erect Hut

when we=have the go ahead

regards

Brice Gordon



--

=C2♦ please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by

return e-mail or by e-mail to jeevacation@gmail.com, and<=r>destroy this communication and all copies thereof,
including all atta=hments. copyright -all rights reserved