
From: jeffrey E. <jeevacation@gmail.com>
Sent: Wednesday, October 19, 2016 4:52 PM
To: brice gordon
Subject: Re: LSJ RO Plant

Manual overide ok

On Wednesday, 19 October 2016, brice =ordon <[REDACTED]> wrote:
<mailto:[REDACTED]>

Jeffrey

The RO plant on LSJ is still down
Reefco was out yesterday to review situation
16 x 32 MA fuses had taken a hit
Even after these where replace the plant would still not operate
TSG have been contacted and are working remotely to determine problem
Danny is trying to figure out away to bypass control program and run plant =anually At this time there is enough water for 2, possible three days
We should know by 3pm if we can run system manually

Sent from my iPhone

--

=A0 please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com>, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved

--001a114f7e848bb1df053f3aa03f-- conversation-id 65728 date-last-viewed 0 date-received 1476895917 flags 8590195713 gmail-label-ids 7 6 remote-id 654148