
From: Leighton Allenby <lallenby@gmail.com>
Sent: Wednesday, August 19, 2015 3:48 PM
To: jeffrey E.
Cc: Richard Kahn
Subject: Re:

The electrical motor is for the street side overhead door =o raise and lower the door at the hanger. The motor wasn't working.♦=A0 The electrician found a short in the wires and fixed. It is now working= Jermaine supervised and confirmed it is working.

Leighton Allenby=/div>
Director of Prope=ties

[REDACTED]

On Wed, Aug 19, 2015 at 11:43 AM, jeffrey E.=<jeevacation@gmail.com <mailto:jeevacation@gmail.com> > wrote:

also last week i asked what the hangar door moto= wass? do we know now?

--

♦=A0 please note

The information contained in this communication is<=r>confidential, may be attorney-client privileged, may constitute insid= information, and is intended only for the use of the addressee. It is =he property of JEE

Unauthorized use, disclosure or copying of thiscommunication or any part thereof is strictly prohibited and may be un=awful. If you have received this communication in error, please notify =s immediately by return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com> , and destro= this communication and all copies thereof, including all attachments. =opright -all rights reserved