

---

**From:** Zorro Ranch <[REDACTED]>  
**Sent:** Tuesday, August 18, 2015 1:05 PM  
**To:** Jeffrey Epstein  
**Cc:** ZDC Office  
**Subject:** ZDC Well 4 Pump Station

Jeffrey

Last night a power surge caused the main booster pumps at well 4 to hammer b=dly and split a y connection to the main water line Resulting in no water to MH RC and Larry's Locating parts this morning, at best we should have it repaired by tonight a=d be able to pump water again tomorrow We have enough in water in reservoir and can pump water from Dakota Backup t=nk to maintain basic operations at main house Domestic water production and cooling tower operation RC and LV will have very limited supply until repair is done Regards Brice

Sent from my iPhone=?xml version=.0" encoding=TF-8"?> <!DOCTYPE plist PUBLIC "-//Apple//DTD PLIST 1.0//EN"

"http://www.apple.com/DTDs/PropertyList-1.0.dtd">

```
<plist version=.0">
<dict>
  <key>conversation-id</key>
  <integer>107196</integer>
  <key>date-last-viewed</key>
  <integer>0</integer>
  <key>date-received</key>
  <integer>1439903130</integer>
  <key>flags</key>
  <integer>8590195713</integer>
  <key>gmail-label-ids</key>
  <array>
    <integer>6</integer>
    <integer>2</integer>
  </array>
  <key>remote-id</key>
  <string>535275</string>
</dict>
</plist>
```