
From: Ann Rodriguez [REDACTED]
Sent: Thursday, January 4, 2018 5:21 PM
To: jeevacation@gmail.com; Rich Kahn
Subject: Cistern update
Attachments: image1.jpeg; image2.jpeg; image3.jpeg; image4.jpeg; Untitled attachment 00030.txt

4in pipe in cistern 2 has blown. Danny V. & Danny E. has repaired the same p=pe 3x already. I'm calling "Just Plastic Plumbing" t= come out to LSJ and Assist Danny V. since Danny E. is on Vacation.

Danny said that it's a 1 day fix if they come out with all the parts=needed. I'll try to get them to come out today if possible