
From: Jeffrey Epstein <jeevacation@gmail.com>
Sent: Saturday, October 29, 2011 12:22 AM
To: [REDACTED]
Cc: Rich Kahn; Darren Indyke; Gary Kerney
Subject: Re: LSJ Transformer

what happened, who was to maintain it? it couldn't have gone to empty in one day?

On Fri, Oct 28, 2011 at 2:33 PM, [REDACTED] <[REDACTED]> wrote:

update:

we have shut down the transformer and are running on Generator power
Oil level is indicated at empty, to fill would require 530 gallons of non inhibited mineral oil
Estimated Cost \$900.00 @ 55 gallons = \$8700.00
Mike Glidden will be forwarding options for repair and/or replacement early next week
please note the following:
To repair will require removal and shipping to Florida
Transformer was built to design spec,
New transformer will be stainless steel spec
Investigating alternative oil price

--

[REDACTED]
Little Saint James
USVI
Phone: [REDACTED]

--

*****=*****

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of Jeffrey Epstein Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved