
From: Richard Kahn [REDACTED]
Sent: Thursday, December 14, 2017 6:37 PM
To: jeffrey E.
Subject: Fwd: wapa cable

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

Begin forwarded message:

From: =/b>Ann Rodriguez <[REDACTED]>

Subject: =/b>Re: wapa cable

Date: =/b>December 14, 2017 at 1:26:42 PM =ST

To: =/b>"Hugo Hodge Jr." <[REDACTED]>

Cc: Richard Kahn <[REDACTED]>

Ann R.

On Dec 14, 2017, at 1:48 PM, Hugo Hodge Jr. =lt
<mailto:[REDACTED]> wrote:

The mud and sludge is probably attributed to water conditions during the hurricanes.

The switch I'm referring to is the one next to the warehouse that the cover was built around. That cover is in violation as well.

On Dec 14, 2017, at 1:05 =M, Richard Kahn <[REDACTED]>
<mailto:[REDACTED]> wrote:

hugo two questions:

a) how does =his mud and sludge build up? should we be doing this quarterly? =nnually?
-> is this hurricane related? =nbsp;an accumulation over years?

b) =lease expand on switch you are referring to below

thank you

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th =loor
New York, NY 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

On Dec =4, 2017, at 12:01 PM, Ann Rodriquez [REDACTED] wrote:

I have Big Lorn Sewage on LSJ right now doing the pump out of =he sludge.

Ann R.

On Dec 14, 2017, at =2:56 PM, Hugo Hodge <[REDACTED]>
<mailto:[REDACTED]> wrote:

I don't think we are at that point yet. They =attempted to pump the water out of the manhole this morning but it was =illed with mud and sludge. A sewage truck is to go over and clear the =anhole this afternoon. Tomorrow morning Denny's guys will go =ack and see what needs to be done to repair/replace the splice. That is =hen I will find out if we have enough slack in the cable or if =dditional cable is needed.

Most =importantly, the switch is in desperate need of replacement.

wrote:

On Dec =4, 2017, at 10:55 AM, Richard Kahn <[REDACTED]>

thanks for all your help yesterday
it appears =e do not have any extra cable on LSJ
can you please help =s purchase from WAPA or any vendor that can supply

ASAP

thank you

Richard =ahn
HBRK Associates Inc.
575 Lexington =venue 4th Floor
New York, NY 10022
tel = [REDACTED]
fax [REDACTED]
cell = [REDACTED]

=