
From: Richard Kahn <[REDACTED]
Sent: Monday, December 4, 2017 9:43 PM
To: jeffrey E.
Subject: Wapa update

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
[REDACTED]

Begin forwarded message:

From: =/b>Hugo Hodge <[REDACTED]

Subject: =/b>Re: time to =peak

Date: =/b>December 4, 2017 at 4:41:30 PM =ST

To: =/b>Richard Kahn <[REDACTED]

Cc: ann rodriquez <[REDACTED]

I just landed in Vancouver =nd I'm headed straight to a meeting.

In short, the fuse did not hold to energize the cable on =riday when there was load or on Sunday when Danny took all of the load =ff the system.

I have WAPA testing the =able, just as a precaution. It was checked before and was fine. I also =ave them running a series of test in the manhole and at the Pole to =ake sure all the connections are good.

Once =ll of this is completed we will give it a try again.

I'm back next week so if it doesn't hold the =ext time I will go to LSJ with WAPA, this has already been discussed =nd confirmed with them, to figure out what is going on and get LSJ back =nline.

On Dec 4, 2017, at 11:13 AM, Richard Kahn <[REDACTED]> wrote:

can we talk later today for an update on LSJ wapa
thank you

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th =loor
New York, NY 10022
[REDACTED]

=