
From: brice gordon - [REDACTED]
Sent: Thursday, July 5, 2018 12:44 PM
To: jeevacation@gmail.com
Cc: Richard Kahn; [REDACTED]
Subject: LSJ Cabana 3
Attachments: IMG_2112.jpg; Untitled attachment 00026.txt

Morning

Last night a blocked condensate line, caused water to back up in the AC pan and overflow into the Bathroom of Cabana 3 It's been fixed, but as you can see the wood flooring and finish have been damaged Will review options regarding repair of floors Regards Brice