
From: jeffrey E. <jeevacation@gmail.com>
Sent: Thursday, August 2, 2018 6:53 PM
To: Brice Gordon
Subject: Re: ZM VD Well B

yes

On Thu, Aug 2, 2018 at 2:47 PM, Brice Gordon [REDACTED] <mailto:[REDACTED]> wrote:

Good Afternoon

attached for your review

The Existing VFD which drives the Well Pump at Well B is Failing

Original Cost: 14002.00 with Enclosure

The New unit is larger in capacity 25Hp vs the Existing 7.5 HP

[REDACTED]
Date: Mon, Jul 23, 2018 at 5:04 PM Subject: ZM VD Well B

To: Rich Kahn [REDACTED] <mailto:[REDACTED]>

Cc: Zorro-Ramirez [REDACTED] <mailto:[REDACTED]>

Rich

Attached for your review

Proposal for the replacement for the VFD for the Well Pump in Well B, \$13,598.00
2015 Proposal for existing VFD, \$13,412.00 Rogers Drilling

2015 the Well Pump for Well B was upgraded to 50 gpm 3 phase motor, in doing so a single phase to 7.5hp 3 phase VFD was installed.

The existing drive is very susceptible to voltage fluctuation and as of date the VFD needs to be reset frequently during the day.

This situation is making it very difficult to achieve a constant water supply for domestic and irrigation purposes. It will need to be addressed if we are to achieve the qty of water required under the permit E 7871. =C2

RMC Electric sourced the company that will supply the drive and the support

The new drive is 25hp vs the existing 7.7hp drive, this will handle the power fluctuations from the power company.

Can we proceed with purchase and install

regards

Brice Gordon

Staley, NM

LSJ-GSJ, USVI

Ph [REDACTED]

--

Brice Gordon

LSJ-GSJ, USVI

Ph [REDACTED]

=/div>

--

⚡=A0 please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved

--00000000000087aa550572785144-- conversation-id 311003 date-last-viewed 0 date-received 1533235973 flags 8590195713 gmail-label-ids 6 7 remote-id 841443