
From: J <jeevacation@gmail.com>
Sent: Thursday, December 27, 2018 3:00 PM
To: brice gordon
Cc: Richard Kahn; Kyle reavis; michael glidden; [REDACTED]
Subject: Re: LSJ Cabana 3

jays plumber AGAIN!!!!

On Thu, Dec 27, 2018 at 9:50 AM brice gordon [REDACTED] wrote:

Sorry for the news !!

A hot water line to the thermostatic shower valve in Cabana 3 blew apart last night

The wall between the bathroom and shower that houses the valve filled with water, which resulted in water seeping into the bathroom and bedroom

The floors in both areas will need to be replaced, along with the Bedroom Rtg and most probably the bathroom Cabinetry

All other furnishing have been removed and placed in Cabana 4

Repair to line is in progress

I will forward a update at 4.30 tonight

Brice

Sent from my iPhone

--

=A0 please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE. Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved

--0000000000002e2577057e023205-- conversation-id 317533 date-last-viewed 0 date-received 1545922779 flags 8590195713 remote-id 885517