

---

**From:** Richard Kahn [REDACTED]  
**Sent:** Friday, September 7, 2018 8:01 PM  
**To:** jeffrey E.  
**Subject:** prosolar

maybe=brice emails about solar being down were to cover himself with excuse =s no one was staying on GSJ there games and lies are =xhausting..

Richard Kahn  
HBRK Associates Inc.  
[REDACTED]

Begin forwarded message:

From: =/b>LSJ GSJ [REDACTED]

Subject: =/b>Re: Friday June =9th

Date: =/b>September 7, 2018 at 3:55:09 PM =DT

To: =/b>brice gordon <bgordon.lsj@gmail.com>

Cc: Dan Prosolar <[REDACTED]>, Marcelo [REDACTED], Brian Walden [REDACTED]

=richard Kahn [REDACTED]

, michael glidden <[REDACTED]>

Good Afternoon to =ll  
As of time and date system is up and =unning  
I will review again later this =evening and give an update to all  
Warmest =egards  
[REDACTED]

On Sep 7, 2018, at 1:22 PM, brice gordon <[REDACTED]> wrote:

[REDACTED]  
Please advise if solar =rid is maintaining load on GSJ  
Thank =ou

Sent from my iPhone

On Sep 7, 2018, at 10:54 AM, Richard Kahn =  
[REDACTED] > wrote:

is solar back up?  
if so =lease advise what issues were..  
thank =ou

Richard Kahn  
HBRK Associates Inc.

[REDACTED]

On Sep 5, 2018, at 7:22 AM, brice gordon [REDACTED] wrote:

Morning  
Same =ssue no power again  
Sunny islands =ead  
Sunny boys flashing =yellow  
Please as to what you would like to =o  
Brice

Sent from my iPhone

On Sep 4, 2018, at 12:11 PM, Dan Prosolar <[REDACTED]> wrote:

good morning all! hope =everyone had a great weekend.. minus GSJ with no power.

i feel very good about my visit today. i was =eceiving error codes pertaining to an OVER-VOLTAGE situation. this is =reat news considering we have been fighting the opposite problem since =he hurricanes. i have had the system set to perform at the absolute =eek voltage it can to avoid loosing power. this maximum voltage setting =eeters the system on the edge of its capabilities. as we see now it has =btained and exceeded its voltage setting limits on the sunny islands. =here is no damage done, only the inconvenience of it shutting down to =protect itself. Today i throttled back the target voltage by 1v. this =hould prevent more shutdowns due to over voltage. i think we have got =his system dialed in.

All the best, Dan Chrisman

On Mon, Sep 3, 2018 at 6:57 PM, brice gordon

> =rote:

Good Evening

The solar system is down on GSJ  
No power =unny islands  
Sunny boys seem to be in =alarm  
Cluster box no power  
Please advise as to Dans schedule  
Regards =rice

Sent from my =Phone

On Jul 11, =018, at 2:10 PM, Marcelo

wrote:

Good =fternoon Richard,

Please =ee the below email containing Dan's summary of what actions he =erformed on his last visit to GSJ.

Regards, =/span>

Marcelo =erez

Project Manager

941.275.5186

<401A334B1BB040D0BBA29AA3089AB844[431569].jpg>

From: Dan Prosolar [REDACTED]  
Sent: =/b>Wednesday, July 11, 2018 1:10 PM  
To: =/b>Marcelo [REDACTED]  
Subject: Re: FW: =riday June 29th

Good =fternoon all, sorry for the delay my email had an issue and became =nlinked so I wasn't receiving these untill now. Regarding GSJ =ere is what's been achieved.

-all Aquion battery =odules are wired to bypass the corroded, water damaged circuit boards =hat could interfere with charging profiles.

-sunny islands (6) =ere downgraded to firmware version 6.0.02. This was done to allow a =roader, linear charge profile to be set

-charging parameters =re now based on voltage set points rather than state of charge =alculations done internally with different references.

-max charge voltage =as been set to 58.5V and the batteries will not stop charging untill a =oltage 1.5V over the set limit is a achieved for 15 seconds. This gives =hem the ability to serpase the previous charge voltage of 56.7V

- the main issue =hat caused so much down time before was as follows. A target charge =oltage that matched the Aquion batteries was not possible with the =previous profile. Compiled on that was faulty Aquion circuit boards =reventing the batteries from properly charging to a suitable voltage. =quion, as we know, is no more, so it's impossible to obtain =eplacement parts. Aquions bms never met the as advertised performance =nd created more issues than we could have imagined. In short, the =hanged I made allowed for a higher, more suitable battery voltage to be =chieved and prevents the premature shut down we saw before.

Again, sorry for the =elay, hope all is well

Thanks

Dan Chrisman

Senior Technical Specialist

Prosolar=LLC

From: Richard Kahn [REDACTED]

Sent: =/b>Wednesday, July 11, 2018 10:30 AM

To: =/b>Brian Prosolar [REDACTED]

Cc: Brad-Sternak; michael.gildden [REDACTED]; Brice Gordon [REDACTED]

Subject: Re: Friday June 29th

can we do thursday morning or anytime friday

when can expect =an's summary?

please =advise

thank =ou

Richard Kahn  
HBRK =ssociates Inc.

On Jul =0, 2018, at 2:18 PM, Brian Prosolar <

wrote:

Afternoon =ichard,

Brad is traveling to San Francisco for a conference and I'm boarding a plane to STX. I've asked Dan to write a synopsis of his efforts and we have been monitoring for proper function. I'll relay this tomorrow once he's finished.

We're still evaluating but all is functioning as intended for the moment. Additional monitoring and confirmation are needed since the weather over the last week has been extremely cloudy.

Would it be possible to have our call on Thurs. afternoon at 3 EST?

Regards,

Brian Walden  
ProSolar America, Inc

Director of Operations

[REDACTED]

On Jul 10, 2018, at 1:50 PM, Richard Kahn [REDACTED]

[REDACTED] > wrote:

i have not yet heard back from anyone on a time to speak

please advise

thank you

Richard Kahn  
HBRK Associates Inc.

[REDACTED]

On Jul 10, 2018, at 5:36 PM, Richard Kahn [REDACTED] wrote:

can we please arrange a call for tomorrow to review current status of GSJ solar

thank you

Richard Kahn  
HBRK Associates Inc.



wrote:

On Jun 9, 2018, at 1:36 PM, Brian Prosolar



Afternoon =ich,

I =believe the normal boat arrival time is 8 or 8:30 a.m. in Redhook. =nbsp;

Dan =ill be there.

Regards,

Brian Walden  
ProSolar America, =lc

Director of =perations



On Jun 29, 2018, at 1:20 PM, Richard Kahn =lt;

wrote:

please =onfirm what time you will be arriving at GSJ on Monday

thank you

Richard Kahn  
HBRK Associates Inc.

[REDACTED]  
On Jun =8, 2018, at 1:42 PM, Brian Prosolar <

wrote:

Afternoon Richard,

We're still =trying to have a final discussion with Stefan as well as track down =multiple 128MB or smaller SD cards to reboot the Sunnyboy inverters. =e're moving as quickly as we can in order to execute the =onversion plan but it looks like we have to push to Monday. Dan has =shown Michael how to get the system back up and operating in the event =f it dropping offline and that is working for the interim.

Regards,

Brian Walden

[REDACTED]  
On Jun 28, 2018, at 11:08 AM, Richard Kahn =lt;  
[REDACTED] wrote:

please =onfirm that you will be at GSJ tomorrow to work on the Solar  
thank you

Richard Kahn  
HBRK Associates Inc.

wrote:

On Jun 5, 2018, at 7:27 PM, Brian Prosolar <

I want to ensure we have the PCB bypass discussion with the engineers prior to

the visit and will try to expedite.

Brian Walden  
EE/RE Consultant

On Jun 25, 2018, at 5:05 PM, Richard Kahn <

> wrote:

we are without any solar currently

can you please try to have dan come sooner

thank you

Richard Kahn  
HBRK Associates Inc.

On Jun 5, 2018, at 4:31 PM, Brian Prosolar <

wrote:

Afternoon =ichard,

I have Dan on the =chedule to head to GSJ on Friday.

Regards,

Brian Walden

ProSolar America, =lc

Dir. =f Operations

[REDACTED]  
On Jun 25, 2018, at 3:30 PM, Richard Kahn [REDACTED]  
> wrote:

can you please advise when your men can come =n and fix our solar system  
thank you

Richard Kahn  
HBRK Associates Inc.

[REDACTED]

<401A334B1BB040D0BBA29AA3089AB844[431569].jpg>

<=div>

Prosolar Systems

Caribbean: 340-201-4752

Florida: =50-222-3554

Let's Get Social

<=blockquote>

=