
From: Richard Kahn <[REDACTED]>
Sent: Friday, September 7, 2018 6:30 PM
To: jeffrey E.
Subject: Fwd: GSJ

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
[REDACTED]

Begin forwarded message:

From: =/b>Brian Prosolar <[REDACTED]>

Subject: =/b>GSJ

Date: =/b>August 13, 2018 at 8:06:02 PM =DT

To: =/b>Richard Kahn <[REDACTED]>

Cc: [REDACTED] Brad Spernak
[REDACTED]

Evening Richard,

I'm coordinating with Michael Glidden to schedule a service call this week. No alarms have sounded but I'd like to reinstitute our ProCare process now that the storm recovery has settled into a dull roar.

In addition to the maintenance inspection I've asked Dan to continue executing the engineer from Aquion's direction concerning the circuit boards. Michael and Brice also feel that removing the corroded portions is advisable and I concur. Dan will put together a list of items needed to terminate several terminal ends and will schedule with Michael to find a day that is the least disruptive to perform this work.

After monitoring the system for several weeks under the expected load I'm pleased to report that the remedies put in place are effective.

Regards,

Brian Walden
ProSolar America, Inc
Director of Operations
[REDACTED]

Prosolar Systems



Let's Get Social

=