
From: Richard Kahn <[REDACTED]>
Sent: Wednesday, January 23, 2019 8:54 PM
To: reefcoservices
Cc: Daphne Wallace
Subject: Re: Flagpole AC unit

thank=you

what happened in =abana 2?

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

On Jan 23, 2019, at 3:52 PM, reefcoservices <[REDACTED]> wrote:

Yes, it's done. Piece of paper from the construction in there =ot sucked up into the duct. They are remodeling the kitchen.

Best regards,
David Van Drieson
Reefco Services, Inc.
[REDACTED]

On Wed, Jan 3, 2019 at 3:21 PM Richard Kahn <[REDACTED]> wrote:

were you able to look at flagpole ac =oday
please advise
thank you

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
tel [REDACTED]
fax [REDACTED]
cell [REDACTED]

> On Jan 22, 2019, at 9:24 PM, Work <[REDACTED]> wrote:
>
> Yes, sure will
>
> Warm Regards,
> David Van Drieson
> Reefco Services
>
>> On Jan 22, 2019, at 6:06 PM, Richard Kahn <[REDACTED]> wrote:
>>
>> can you please look at into a knocking sound in the flagpole AC unit tomorrow when onsite
>> thank you
>>
>>
>>
>> Richard Kahn
>> HBRK Associates Inc.
>> 575 Lexington Avenue 4th Floor
>> New York, NY 10022
>> tel [REDACTED]
>> fax [REDACTED]
>> cell [REDACTED]
>>
>>
>>

=