

---

**From:** Richard Kahn <[REDACTED]>  
**Sent:** Thursday, March 7, 2019 9:15 PM  
**To:** michael glidden  
**Cc:** Daphne Wallace; Stephanie Remington  
**Subject:** Fwd: 40x60 bldg.

i =m not sure if you responded and i apologize if you did and i missed =t..  
could you please update on status and next steps as =ee would like ordered asap thank you

Richard Kahn  
HBRK Associates Inc.  
575 Lexington Avenue 4th Floor  
New York, NY 10022  
tel: [REDACTED]  
fax: [REDACTED]  
cel: [REDACTED]

Begin forwarded message:

**From:** =/b>Richard Kahn <[REDACTED]>  
**Subject:** =/b>Fwd: 40x60 =ldg.  
**Date:** =/b>February 22, 2019 at 3:25:25 PM =ST  
**To:** =/b>michael glidden <[REDACTED]>  
**Cc:** =/b>Daphne Wallace <[REDACTED]>, Stephanie Remington <[REDACTED]>

can you please review and reply ASAP  
thanks

Richard Kahn  
HBRK Associates Inc.  
575 Lexington Avenue 4th Floor  
New York, NY 10022  
tel: [REDACTED]  
fax: [REDACTED]  
cel: [REDACTED]

Begin forwarded message:

From: Brian Buck <[REDACTED]>

Subject: RE: 40x60 bldg.

Date: February 21, 2019 at 1:30:57 PM EST

To: michael glidden [REDACTED]

Cc: Daphne Wallace <[REDACTED]>, Richard Kahn <[REDACTED]>, Stephanie Remington <[REDACTED]>

Michael,

I want to put together a drawing for you but I need to clarify a couple of things first.

\* So the building was not erected according to plans, it was modified somewhat in the field? The building was a fully sheeted building. So the erector opened up the left end wall to 8'2 =80 and the back side wall to 10'6" but was sheeted =6" past the roof of the 14" slab. How deep is the retaining wall?

\* Are the (2) 12' x =4' doors on the marked up dwg you sent back (front side wall and right end wall) to be included in these locations? Are we adding a third rollup door in bay #3 of the front side wall where you currently have a 15' rough opening?

Assuming the above is correct this is what I would propose.

We previously had the left end wall as a flush girt condition. I could change it to a bypass girt so that the girt would extend =0"(depth of girt) past the face of the column. This way a) the panel would lap over the retaining wall(if it is 10" or less deep) for a good seal and b) would allow us to shift the columns in =0". This will clear the existing anchor bolts which will be cut off and providing the pier is sufficient in width, would save a whole lot of time and labor on those (4) left end wall columns.

I'd leave the back side wall open to 10'6 =9D, sheet above the roof and provide a wall to roof flashing. I'm assuming the slab is all even elevation?

I think if we change the bay spacings slightly(less than a foot in most cases) we can avoid having to do a lot of the demolition.

What do you think?

Regards,  
Brian Buck

President

Direct [REDACTED]  
Toll Free [REDACTED]  
Web [www.bucksteel.com](http://www.bucksteel.com)  
Follow us on social media!

6855 Lyons Technology Circle = Suite 18 | Coconut Creek FL 33073 1107=Battlewood Street | Suite 221 | Franklin TN 37069 Legal Disclaimer: This =ommunication and any attachments contain information which is =onfidential and may also be privileged. It is for the exclusive use of =he intended recipient(s). If you are not the intended recipient(s) =lease note that any form of disclosure, distribution, copying or use of =his communication or the information in it or in any attachments is =strictly prohibited and may be unlawful. Where the content of this email =s personal or otherwise unconnected with the firm's or its clients' =usiness, Buck Steel accepts no responsibility or liability for such =ontent. E-mail communications cannot be guaranteed to be secure or =rror free, as information could be intercepted, corrupted, amended, =ost, destroyed, arrive late or incomplete, or contain viruses. We do =ot accept liability for any such matters or their =onsequences.

From: michael glidden <[REDACTED]>  
Sent: Wednesday, February 20, =019 4:56 PM  
To: Brian Buck <[REDACTED]>  
Cc: Daphne Wallace <[REDACTED]>; richard Kahn <[REDACTED]>  
<mailto:[REDACTED]>; Stephanie Remington <[REDACTED]>  
Subject: Fwd: 40x60 bldg.

Good afternoon Brian.  
I=thought that this might help understanding how the building was =nstalled. The only openings are as marked up.  
I will gather the information tomorrow that we discussed =

Begin forwarded message:

From: michael glidden = [REDACTED] <mailto:[REDACTED]>  
Subject: 40x60 bldg.  
Date: February 20, =019 at 5:47:48 PM AST  
To: [REDACTED]

Sent from my =Phone

=/div>

=