
From: Richard Kahn <[REDACTED]>
Sent: Friday, February 22, 2019 10:39 PM
To: Jeffrey Epstein
Subject: cabanas

mike did water testing and found the following:

cabana 4 - no water penetration
cabana 3 - leakage on both openings
cabanas 1 & 2 - leak on only 1 opening

mike plans to use a high end calking on the outside and fix immediately..

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
[REDACTED]
[REDACTED]
[REDACTED]

```
<?xml version="1.0" encoding="UTF-8"?>
<!DOCTYPE plist PUBLIC "-//Apple//DTD PLIST 1.0//EN" "http://www.apple.com/DTDs/PropertyList-1.0.dtd">
<plist version="1.0">
<dict>
  <key>conversation-id</key>
  <integer>336483</integer>
  <key>date-last-viewed</key>
  <integer>0</integer>
  <key>date-received</key>
  <integer>1550875162</integer>
  <key>flags</key>
  <integer>8590195713</integer>
  <key>remote-id</key>
  <string>902601</string>
</dict>
</plist>
```