

---

**From:** Ann Rodriguez <[REDACTED]>  
**Sent:** Monday, August 7, 2017 3:21 PM  
**To:** jeffrey E.; Rich Kahn  
**Subject:** R/O Water leak  
**Attachments:** IMG\_9803.JPG; Untitled attachment 00127.txt; image1.JPG; Untitled attachment 00130.txt; image2.JPG; Untitled attachment 00133.txt; IMG\_9804.JPG; Untitled attachment 00136.txt; IMG\_9805.JPG; Untitled attachment 00139.txt; IMG\_9806.JPG; Untitled attachment 00142.txt; IMG\_9807.JPG; Untitled attachment 00145.txt

Danny E. said that Danny V. used the wrong union. Danny V. used irrigation p=rts instead of a water pressure union.

Danny E. is headed to Just plastics to pickup a "schedule 80 union" which is=what should've been used from the beginning because the rest of the piping is a schedule 80