
From: jeffrey E. <jeevacation@gmail.com>
Sent: Wednesday, August 2, 2017 8:46 PM
To: Ann Rodriquez; Daphne Wallace; Rich Kahn
Subject: Re: LSJ Main Generators: Not good

Bad maintenance

On Wed, Aug 2, 2017 at 3:21 PM Ann Rodriquez <a[REDACTED]> wrote:

<=lockquote class="gmail_quote" style="margin:0 0 0 .8ex; border-left:1px=#ccc solid; padding-left:1ex">Hey Bossman,

Danny just told me that the 1st generator sprung a coolant leak (first 6 ph=tos) and the 2nd Generator belt has burst (photos 7&8) 2nd Generator is down. LSJ is currently running on 1 generator at the moment.

He asked if Tap can fix it for him. Tap said it's pretty bad but he can=fix it if we get all the parts. I told Danny V. to call Plan B Generator c=mpany to come out tomorrow morning or asap.

The Generator is running because we had another power outage this morning a=d it blew out the repeater for the R/O again. (last 2 photos)

Not to worry I'm on it...

Ann R.

--

=C2 please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for

JEE

Unauthorized use= disclosure or copying of this communication or any part thereof is str=ctly prohibited and may be unlawful. If you have received this commu=ication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com> , and destroy this communication and all copies thereo=, including all attachments. copyright -all rights reserved

</=iv>

--001a114152bcadd5920555cb5a90-- conversation-id 36440 date-last-viewed 0 date-received 1501706771 flags 8590195713 gmail-label-ids 7 6 remote-id 735784