
From: brice gordon <████████>
Sent: Wednesday, February 8, 2017 5:45 PM
To: Jeffrey Epstein
Cc: LSJ GSJ
Subject: LSJ RO Plant

Jeffrey

████ expressed there was a calcium issue with the water on LSJ. The issue is probably the post water treatment to obtain the correct balance is out of calibration, this is a separate issue to the RO plant itself. Smiley should know how to calibrate this, namely the sulfuric acid injection and calcium carbonate. I have asked Jermaine to get us back online and to place the back up copy to the PLC on the server and a copy to myself. Patrick is not on Island, but he is reaching out to an independent source on STT to come over and review plant and advise what is actually going on.

=/div>
regards

Brice Gordon