
From: jeffrey E. <jeevacation@gmail.com>
Sent: Wednesday, May 16, 2018 9:25 PM
To: brice gordon
Subject: Re: LSJ Cabana 2 and 3 Spetic

Ok replace no problem

On Wed, May 16, 2018 at 10:49 PM brice gordon <[REDACTED]> wrote:
<=div>

FYI

The septic system for Cabanas 2 & 3
will need to replaced

It appears the line to the original tank was abandoned due to a bad blockag=
Unfortunately a above ground water tank was buried, instead of a spetic tan= to handle waste,

The water tank has collapsed

We are also unsure where they piped the overflow at this time !!!!

Probably the green spot on the hill below the Master Bedroom

Sent from my iPhone

--

=C2 please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE Unauthorized use, disclosure or copying of this communication or any part thereof is strictly prohibited and may be unlawful. If you have received this

return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com>, and destroy this communication and all copies hereof, including all attachments. copyright -all rights reserved </div>
--000000000000cb0cf8056c595ac8-- conversation-id 6454 date-last-viewed 0 date-received 1526505914 flags 8590195713 gmail-label-ids 7 remote-id 821876