
From: brice gordon [REDACTED]
Sent: Sunday, January 1, 2017 5:10 PM
To: Jeffrey Epstein
Subject: LSJ RO

Jeffrey

The Profibus repeater for the S=a Water Intake Pumps has been ordered and should be on sight next week This may fix the issue, but all indication lead to a PLC issue =div>Profibus repeater replacement is the first step, respec=fully, I got handed this in Nov, i'm doing everything possible to get =his resolved,

Brice Gordon=strong>

[REDACTED]