
From: Merwin Dela cruz <[REDACTED]>
Sent: Monday, January 2, 2017 8:50 PM
To: jeffrey E.
Cc: Richard Kahn
Subject: Re: BMS is down

Hi sir,
Chiller is back up and running...
=br>
Panel is up and running now. We los= back up battery where panel is connected to that made the panel lose all t=e
programming.

Merwin Dela Cruz
[REDACTED]
[REDACTED] =

On Jan 2, 2017, at 2:02 PM, Richard Kahn <richardkahn12@gmail.com <mailto:richardkahn12@gmail.com> =gt; wrote:

any updates?

Richard Kahn
HBRK Associates Inc.<=div>
[REDACTED]
[REDACTED]
[REDACTED]
[REDACTED]

On Jan 2, 2017, at 11:43 AM, Merwin Dela cruz <[REDACTED]>
<mailto:[REDACTED]> wrote:

Hi=sir,
I'm sorry to tell you that our BMS system that controls t=e chillers and pumps are down. I was in contact
with Siemens and waiting fo= their call.

I'm so sorry....
<=r class="">Merwin [REDACTED]
[REDACTED]
[REDACTED]

=