
From: jeffrey E. <jeevacation@gmail.com>
Sent: Thursday, December 15, 2016 12:40 AM
To: Richard Kahn
Subject: Re: TSG update

why still manual?

=div class="gmail_quote">On Wed, Dec 14, 2016 at 7:31 PM, Richard Kahn <
<mailto: > > wrote:

how can system can run so fa= off course...
i will question tomorrow when i speak with Bob..
<=iv>not sure why Brice could not come to this conclusion with Bob 2 weeks a=o...

Richard Kahn
HBRK Associates Inc.

New York, NY 10022
[REDACTED]

Begin forwarded message:

From: Ann Rodriquez <[REDACTED]>=/a>>

Subject: <=b>Re: TSG updates?

Date: December 14, 2016 at 5:24=08 PM EST

To: =/span>Richard Kahn <[REDACTED]> >

Bob told us that if =he membranes tested 800 then it would be normal and if it test 1000 then i= would be bad. Our main membranes tested 7000 which is pure salt water tha= was contaminating the cistern water.

Tomorrow morning at 10am Bob wil= come out to rebuild the manifold, change the port adapter and work on the=intake under the dock. After the maintenance service is done it will still=run manually but the water will be purifying properly.

Bob will=send a report tomorrow afternoon.

Ann R.

On Dec 14, 2016, at 4:42 PM, Richard Kahn <[REDACTED]>
<mailto:[REDACTED]> > w=ote:

Richard Kahn
HBRK Associates Inc.
575 Lexington Avenue 4th Floor
New York, NY 10022
[REDACTED]

--

=div dir="ltr"> please note
=div>The information contained in this communication is
confidential, may be attorney-client privileged, may
constitute inside information, and is intended only for
the use of the addressee. It is the property of
=EE
Unauthorized use, disclosure or copying of this
communication or any part thereof is strictly prohibited
and may be unlawful. If you have received this
communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com
<mailto:jeevacation@gmail.com> , and
destroy this communication and all copies thereof,
including all attachments. copyright -all rights reserved