
From: Ann Rodriguez [REDACTED]
Sent: Thursday, December 12, 2013 7:19 PM
To: Jeffrey Epstein
Subject: LSJ Quotation- R/O plant down
Attachments: image001.png; Untitled attachment 00484.htm; LSJ Touchscreen proposal.doc; Untitled attachment 00487.htm

Hey Bossman,

=he computer that control the R/O plant is not working and the screen is not=visible to find the problem. LSJ is unable to turn salt water into fresh wa=er until we get a new computer screen for the R/O system.

<=r>

We have a month worth of water if we do not use the irrigation=system.

Please advise,
Ann R.

Begin forwarded=message:

From: Patrick A=ams [REDACTED] <mailto:[REDACTED]>><=r>Date: December 12, 2013
at 3:04:30 PM AST
To: [REDACTED]
Cc: M=rk Banzin [REDACTED] <=a>, Bob Petersen <[REDACTED]>
[REDACTED] <mailto:[REDACTED]>
Subject: LSJ Quotation

=/blockquote>

=

Ann,

= Please see the attached quotation for r=placing the Siemens touchscreen for the Little St. James SWRO system. I ♦=99ve not been out there to look at this personally, but I did get online wi=h the machine today and have a look at the PLC and I could not make a connection with the touchscreen. I a=so talked with Danny about what had transpired, but I am not certain that t=is will be the only issue and unfortunately, we will not know until the tou=hscreen is replaced and the plant re-started. I will remind you that three high pressure tubes blew up causin= the touchscreen to be flooded with saltwater, so I'm sure that the=e is at least one other problem with the machine that will have to be dealt=with.

Call me if you have any questions.

Patrick Adams

USVI Operations Manager</=>

Office: [REDACTED]:=p>

Cell: [REDACTED]

Fax: [REDACTED]

=

=