

---

**From:** Richard Barnett <[REDACTED]>  
**Sent:** Wednesday, March 14, 2012 7:05 PM  
**To:** jeffrey Epstein  
**Subject:** FW: Water Treatment  
**Attachments:** EcoSAFE Solid Feed System Epstein.docx

Mr Epstein here is the overview of the new tablet chemical feed system =3B for the cooling tower that you requested more information =3B on and we discussed at the meeting today . Richard.

---

From: [REDACTED]  
To: [REDACTED]  
Subject: FW: Water Treatment  
Date: Thu, 1 Mar 2012 17:12:31 +0000

Hi Rich I would like to up grade to this chemical feed syste= for the cooling tower at 71st street , please re=d the overview I feel this will be a much better system,= check out the last page for the pricing , w= need to do this asap. I will call clarity to get a comparison of w=at we spend currently a year on chemicals and what savings will be=if any with the new system i will forward you this information&nbs=;to help with your decision for the cost approval= Thanks RB.

---

To: [REDACTED]  
Subject: Water Treatment  
From: [REDACTED]  
Date: Wed, 29 Feb 2012 22:49:07 -0500

Hey Rich,

I just wanted to follow up again with the proposal for the solid feed =ooling tower chemical. Two of the 3 pumps, after e=periencing difficulties have failed. Chemical pumps fail and need to be replaced periodically. The =ew program I have provided will no longer require pumps and the new system=will never mechanically fail. The system has no working parts.

Please look at the attached proposal. Please let me know how t= procede. With the current system conditions we need to make some =hanges.

Pete  
=