
From: Brice Gordon <[REDACTED]>
Sent: Wednesday, September 2, 2015 3:02 AM
To: jeffrey E.
Subject: Re: ZDC Grade Stake NE Corner 9'4"
Attachments: ZDC PB NE Corner Grade.pdf

Jef=rey

=div class="gmail_default" style="font-size:small">attached for your review, photo showing fill grade requirement
Drawings, top and side view showing outline of proposed work let me know if you require any more detail or info

regards Brice

On Tue, Sep 1, 2015 at 1:50 PM, jeffrey E. <jeevacation@gmail.com</=>> wrote:

dra= on a piece of paper i dpn't follow

O= Tue, Sep 1, 2015 at 12:52 PM, Brice Gordon <[REDACTED]> =/span> wrote:

Jeffrey

attached for your reference are photos showing=the grade stake (GS) at the NE Corner
As shown on sketch from Tim Oden the required=amount of fill is 9"4" to meet grade at the NW Corner
closet to =H

The Plan would be to use a lot of rocks and lose rock material for first stage of fill and then top off with 4 to 5 feet of compacted dirt. Dirt and rocks would extend 25 to 30 feet past edge of proposed layout in this corner.

Are you OK with this?

regards Brice

--

Br=ce Gordon
Stanley, NM

Ph: <= href="tel:%28505%29%20934%202809" value="+15059342809" target="_bla=k">(505) 934 2809

--
please note

The information contained in this communication is confidential, may be attorney-client privileged, may constitute inside information, and is intended only for the use of the addressee. It is the property of JEE

communication or any part thereof is strictly prohibited and may be unlawful. If you have received this communication in error, please notify us immediately by return e-mail or by e-mail to jeevacation@gmail.com <mailto:jeevacation@gmail.com>, and destroy this communication and all copies thereof, including all attachments. copyright -all rights reserved

--
Brice Gorron
Stanley, NM

Ph: [REDACTED]